

OFFICE OF THE REGISTRAR :: DIBRUGARH UNIVERSITY :: DIBRUGARH

No. DU/RG/B.01.07/15/0356 Date: 19/05/2015

Notice Inviting Quotation

Sealed quotations are invited from reputed firms/authorized dealers for the supply and installation of Silent D.G. Set at L.N.B. Library, Dibrugarh University as per specifications mentioned below. The quotations will be received by the undersigned on or before 04/06/2015 upto 11:00 A.M. and will be opened on the same date at 11:30 A.M. in the presence of the intending quotationers or their authorized agents.

SL. No. Particulars	Preferred Brand	Qty.
01 40 KVA Silent D.G. Set: Frequency: 50 Hz, Noise Level: < 75 Fuel Consumption (at 100 % Load): 9.2 Ltr/Hr Fuel Tank Capacity: 100 Ltrs., Number of Cylinder: 3 Cubic Capacity ² : 3.12 Ltrs., Lube Oil Sump Capacity: 8.0 Ltrs. Lube Oil Change Period: 500 Hrs., Rated Speed: 1500 RPM, Voltage: 415 3Ø Alternator Insulation Class: Class H	Kirloskar Green	1 Nos.

Terms and Conditions:

- 1. No separate quotation paper will be issued from the office. Quotation should be submitted in the Supplier's Letter Pad with supporting documents.
- 2. The University reserves the right to accept or reject any or all the quotations without assigning any reason.
- 3. The quantity mentioned may be increased or decreased at the time of order as per actual requirement.
- 4. Payment will be made only after the successful completion of the job and after receipt of the materials in good condition.
- 5. The quotation should be addressed to the "Registrar, Dibrugarh University, Dibrugarh 786004" super scribing the Quotation Notice Number on the envelope.
- 6. Tendering firm should clearly indicate Installation Charge, VAT/Taxes etc. (if any) in their quotation.
- 7. The tendering firm must take the responsibility of installation of the D.G. Set.

Sd/-

Registrar

Dibrugarh University

Copy to:

- 1. The Deputy Registrar (F&A) D.U. for information.
- 2. Dibrugarh University Website.
- 3. Notice Boards.
- 4. Office File.

Sd/-

Registrar

Dibrugarh University