



**OFFICE OF THE REGISTRAR :: DIBRUGARH UNIVERSITY :: DIBRUGARH**

No. DU/RG/B.01.07/18/2906

Date: 05.09.2018

**Notice Inviting Quotation**

Sealed quotations are invited from reputed firms/authorized dealers/suppliers for the supply and installation of Dehumidifier at the Central Sophisticated Instrumentation Centre, Dibrugarh University as per specification mentioned at Annexure-I. The quotations will be received by the undersigned on or before **17.09.2018 upto 11:00 A.M.** and will be opened on the same date at **11:30 A.M.** in the presence of the intending quotationers or their authorized agents.

**Terms and Conditions:**

1. No separate quotation paper will be issued from the office. Quotation should be submitted in the Supplier's Letter Pad with supporting documents.
2. The University reserves the right to accept or reject any or all the quotations without assigning any reason.
3. The quantity as mentioned may be increased or decreased at the time of order as per actual requirement.
4. Payment will be made only after the successful receipt of the materials in good condition.
5. The quotation should be addressed to the "**Registrar, Dibrugarh University, Dibrugarh – 786004**" super scribing the Quotation Notice Number on the envelope.
6. ***Any kind of Taxes/GST (if any) or any kind of installation or other charges must be clearly indicated in the quotation.***
7. In the event of any kind of holiday, the quotations shall be opened on the next working day.
8. The tendering firm must have proper PAN/GST No. and the same shall have to be enclosed with the quotations.

**Sd/-**  
**Registrar**  
Dibrugarh University

Copy to:

1. The Assistant Registrar (F&A), D.U. for information.
2. Notice Boards.
3. Office File.

**Sd/-**  
**Registrar**  
Dibrugarh University

<b>Specification for Dehumidifier (Preferred Brand: Boy Air)</b>		
<b>Sl. No.</b>	<b>Parameter</b>	<b>Required Specifications</b>
<b>01</b>	Dehumidifier coverage area	≥5000 cubic feet area
<b>02</b>	Extraction Capacity @ 30 <sup>0</sup> C – 80% RH	≥ 50 Litres/Day
<b>03</b>	Working Temperature Range	Shall work efficiently at +5 to 40 <sup>0</sup> C
<b>04</b>	Humidity Setting	Humidity Level can be set as per requirement
<b>05</b>	Dehumidify Control System	Automatic dehumidostat control
<b>06</b>	Display	LED/LCD display to view temperature and humidity
<b>07</b>	Refrigerant Type	R-407c or R-410a type
<b>08</b>	Frost Control System	Automatic
<b>09</b>	Water Tank Capacity	≥ 6 Litres
<b>10</b>	Drainage	Shall have provision for continuous drainage
<b>11</b>	Air Circulate Rate	≥ 300 m <sup>3</sup> /h
<b>12</b>	Noise Level	≤ 55dB at 1 Meter Distance
<b>13</b>	Alarm System	Full Water Tank Alarm
<b>14</b>	Power Source / Voltage	230 V / 50 Hz / Single Phase
<b>15</b>	Warranty	3 Years Onsite Warranty

**Sd/-**  
**Registrar**  
Dibrugarh University